

## Multi-generation Renewable Energy System for Dairy Farms: Exergy Analysis

Eric D. Kool<sup>1</sup>, Matthew A. Cuomo<sup>1</sup>, Bale V. Reddy<sup>1\*</sup>, Marc A. Rosen<sup>1</sup>

<sup>1</sup> Faculty of Engineering and Applied Science, University of Ontario Institute of Technology, 2000 Simcoe St. North, Oshawa, Ontario, L1H 7K4, CANADA

\*Corresponding Author: [Bale.Reddy@uoit.ca](mailto:Bale.Reddy@uoit.ca)

**Citation:** Kool, E. D., Cuomo, M. A., Reddy, B. V. and Rosen, M. A. (2018). Multi-generation Renewable Energy System for Dairy Farms: Exergy Analysis. *European Journal of Sustainable Development Research*, 2(3), 37. <https://doi.org/10.20897/ejosdr/2669>

**Published:** July 17, 2018

### ABSTRACT

Exergy analyses of multi-generational micro gas turbine systems are reported for a grid-independent dairy farm in Ontario, Canada, with an aim of being environmentally benign. Onsite anaerobic digesters utilize farm waste to produce carbon neutral biogas for combustion in the micro gas turbine modules. A range of micro gas turbines coupled with absorption refrigeration units and an organic Rankine cycle are driven by the recovered waste heat to meet the cooling and electrical needs of farm sizes between 250 and 6000 cows. Exergy balances are applied to each component as well the overall system configuration, and exergy efficiencies are obtained. Small farm sizes with one absorption cooling unit are found to be more exergy efficient than large farm sizes with more than one absorption cooling unit, but the difference is less than 0.5%. Most of exergy destruction within the micro gas turbine module occurs in the combustion chamber, which contributes 79% of the exergy destruction of the system. Farm sizes between 250 and 6000 cows are observed to be capable of having their cooling and electricity needs met with micro gas turbines ranging in capacity from 100 to 1000 kW output, while exhibiting similar exergy efficiencies.

**Keywords:** renewable energy, dairy farm, exergy analysis, performance, exergy destruction

### INTRODUCTION

Consumers are beginning to demand products that are eco-friendly over their life cycles (Collins, 2011). Accordingly, a case is proposed and analyzed here for a line of milk products having a low carbon-footprint product. A key feature is that all processes in the production are powered by net-zero carbon emission energy sources. Dairy farmers producing milk could be required in the future to operate using such energy sources, and one option is to use bio-fuel produced from farm waste, which can be considered a net-zero carbon emission energy source (Loo and Koppejan, 2010). Thermodynamic analysis and optimization of an anaerobic treatment system for whey is presented (Spachos and Stamatis, 2011). In this study, performance investigations were conducted based on exergy and economic analyses of an anaerobic treatment system of whey and it was concluded that the anaerobic treatment system is a sustainable investment. The impact of food production processes in terms of energy utilization, carbon dioxide emissions and exergy loss in a flavored yogurt production process is investigated (Sorguven and Ozilgen, 2012). The work also identified the direction for the development of new technology in food processing to decrease waste of energy and carbon dioxide emissions. A thermodynamic analysis of a milk pasteurization process assisted by geothermal energy is investigated (Yildirim and Genc, 2015). It was found that highest exergy destruction rate is in the absorber of the vapor absorption cycle. A comprehensive exergy analysis of an industrial-scale yogurt production plant is reported (Jokandan et al., 2015). They noted that the components with high exergy destruction rates are as follows: boiler and air compressor combination of the

**Table 1.** Energy demands for selected farm sizes

Farm size [cows]	Total electricity demand [kW]	Electricity demand without milk cooling electrical load [kW]	Thermal cooling demand [kW cooling]	# of 50 kW ARS Units to meet cooling load
250	28.75	22.7	13.6	1
500	57.5	45.4	27.2	1
1000	115	90.9	54.3	2
1500	172.5	136.3	81.5	2
2000	230	181.7	108.7	3
4000	460	363.4	217.4	5
6000	690	545.1	326.0	7

steam generator, and the ice-water and agitator combination of the refrigeration system. The application of exergy analysis to the dairy industry is reported (Soufiyan and Aghbashlo, 2017). A case study for a yogurt drink production plant is reported. The investigations clearly demonstrated the effectiveness of exergy analysis for determining irreversibilities and losses occurring in a dairy processing plants in order to improve their performance. A comprehensive exergetic performance analysis of an ice-cream manufacturing plant to identify the locations of thermodynamic inefficiencies is conducted (Dowlati et al., 2017). A detailed exergy analysis of an industrial-scale ultrafiltrated cheese production plant based on actual operational data is conducted (Nasiri et al., 2017) in order to provide insights into the performance of the whole plant and its main subcomponents. The study also stressed the role of exergy analysis in performance improvement. The performance of a milk powder production system based on energy and exergy analyses is investigated (Yildirim and Genc, 2017), and observed that greatest the exergy destruction occurs in the evaporator.

In this study, an exergy analysis is performed for various configurations of an integrated multi-generational system which has previously been assessed with an energy analysis (Cuomo et al., 2018). System configurations that can satisfy the energy demands of various farm sizes are considered. We consider the integration of an ammonia based organic Rankine cycle (ORC) to generate power from the exhaust gas exiting the absorption cooling system (ARS) heat exchanger to generate additional electrical power. Sources of exergy destruction, are identified for the biogas-fueled micro gas turbine (MGT) arrangement with heat recovery, and for its components.

Due to the nature of the problem several constraints are placed on the system design:

1. The energy demand of the farm must come directly from the biomass energy generation system. This implies only electricity generated by the unit in excess of the farm's own electricity requirements can be sold to the grid, as the electricity used to run the farm operation must be 100% from a carbon-neutral source.
2. All of the farm's current energy demand ([Table 1](#)) must be met via the system.

The research reported here focuses on an exergy analysis of the system to meet the needs of different sized Ontario dairy farms considering the constraints. The objective of this work is to investigate the exergy efficiencies of various farm sizes with system configurations that meet the required electricity, and cooling loads. Engineering Equation Solver (EES) software is used to assess the second law performance of several system configurations that meet the energy demand for each farm size.

## BACKGROUND


This investigation extends with exergy analysis, an energy analysis of an integrated multi-generation energy system for a dairy farm performed previously by the authors (Cuomo et al., 2018). In that study it was found that micro gas turbines could be effectively utilized to meet the electrical and cooling demands of dairy farms in Ontario, Canada, for farms of various sizes, based on the typical electricity use of an Ontario dairy farm (Clarke and House, 2010). The electricity and cooling demands for various Ontario farm sizes are listed in [Table 1](#).

With the electricity and cooling demand of the dairy farm specified, appropriate MGTs and quantities of ARS units are selected to meet the electrical and cooling load requirements for the various farm sizes identified in [Table 1](#).

The MGT modules selected for this particular study are manufactured by Turbec and Capstone. The capacities along with exhaust temperature, and exhaust flow rate for each of the MGT modules are listed in [Table 2](#).

**Table 2.** Turbine configurations considered and technical specifications of MGT modules (Capstone Turbine Corporation, 2012; Turbec, 2012)

Manufacturer	Turbine model configuration	Capacity (kW)	Exhaust temperature (°C)	Exhaust flow rate (kg s <sup>-1</sup> )
Turbec	T100CHP	100	270	0.80
Capstone	2 X C65	130	309	0.98
Capstone	3 X C65	195	309	1.47
Capstone	C200	200	280	1.30
Capstone	4 X C65	260	309	1.96
Capstone	C400	400	280	2.60
Capstone	C600	600	280	4.00
Capstone	C800	800	280	5.30
Capstone	C1000	1000	280	6.70

**Figure 1.** System layout of topping and bottoming cycles with ORC and ARS subsystems

## SYSTEM MODELLING

The system and its subsystems are modelled thermodynamically using EES and Excel software. The ambient conditions (selected to be the conditions of the dead state) are taken to be 25°C and 101 kPa. General assumptions follow, while subsystem specific assumptions are listed at the beginning of the corresponding sections:

1. Operation is at steady state.
2. Ideal gas models are applicable.
3. Electromechanical conversion losses are negligible.
4. Changes in kinetic and potential energy are negligible.

A general energy rate balance, which can be applied to each system component, can be written as:

$$\dot{Q}_{in} + \dot{W}_{in} + \sum_{in} \dot{m}h = \dot{Q}_{out} + \dot{W}_{out} + \sum_{out} \dot{m}h \quad (1)$$

where  $\dot{Q}$  and  $\dot{W}$  denote the heat and electrical work rates respectively, while  $\dot{m}$  and  $h$  are the mass flow rate and specific enthalpy of the working fluid respectively.

**Table 3.** System State Parameters

State point	Fluid	T [°C]	Description	P [kPa]	Notes
1	Air	25	Ambient conditions	101	Intake drawing at atmospheric pressure
2	Air	Variable	Calculated by model	552	Outlet of compressor, from technical specifications*
3	Air	Variable	Calculated by model	552	
4	Combustion gases	950	Specified by technical specifications of turbine*	552	
5	Combustion gases	Variable	Calculated by model	101	Exhaust at atmospheric pressure
6	Exhaust gas†	Variable	Set by turbine exhaust conditions	101	
7	Exhaust gas†	Variable	Calculated by model, depends on # of ARS units	101	
8	Exhaust gas†	150	To prevent component damage	101	
9	Water	105	Required inlet water temp. for ARS*	169	ARS water pressure**
10	Water	115	Specified water outlet temp. for ARS*	169	
11	Ammonia	45.6	Calculated by model	3830	Recommended operating pressures for an optimized ammonia based ORC**
12	Ammonia	77	Required inlet ORC turbine inlet temperature**	3830	
13	Ammonia	45	Recommended condensation temperature***	1780	
14	Ammonia	45	Recommended condensation temperature***	1780	

†Modelled as air \*Data from (Capstone Turbine Corporation, 2012; Turbec, 2012) \*\*Data from (SolarNext, 2008) \*\*\*Source reference (Hettiarachchia et al., 2006)

A general exergy rate balance, also applicable to each component, can be expressed as follows:

$$\left(1 - \frac{T_0}{T_b}\right) \dot{Q}_{in} + \dot{W}_{in} + \sum_{in} \dot{m} ex = \left(1 - \frac{T_0}{T_b}\right) \dot{Q}_{out} + \dot{W}_{out} + \sum_{out} \dot{m} ex + \dot{E}x_d \quad (2)$$

where  $T_0$  and  $T_b$  are the dead state and boundary temperatures respectively,  $\dot{E}x_d$  is the exergy destruction rate and  $ex$  is the specific exergy, defined as:

$$ex = (h - h_0) - T_0(s - s_0) \quad (3)$$

Here,  $h$  and  $s$  are the specific enthalpy and entropy of the working fluid at the actual state with the dead state being represented by  $s_0$  and  $h_0$  respectively.

### Topping Cycle Model

The MGTs were modelled thermodynamically with EES utilizing manufacturer technical specifications, including operating pressures, fuel flow rate, electrical efficiency, exhaust gas flow rate, exhaust temperature, and turbine inlet temperature (Capstone Turbine Corporation, 2012; Turbec, 2012).

In order to model the turbine modules according to the given specifications, the effectiveness of the regenerator as well as the isentropic efficiencies of the compressor and turbine are required. The effectiveness of the regenerator is taken to be 84%, and the turbine and compressor isentropic efficiencies are both taken to be 72%.

The compressor increases the temperature and the pressure of the air, which is heated as it enters the regenerator. The inlet stream to the regenerator is heated by the hot flue gases from the turbine exhaust, which enter the opposite end of the regenerator, in a counter flow configuration. The compressed air reaches the maximum cycle temperature with the firing of biogas in the combustion chamber. The hot combustion gases then expand through the turbine; the turbine shaft is connected to an electrical generator. The high temperature exhaust gases pass through the regenerator to provide preheating to the high pressure stream before being released to the atmosphere.

Assumptions regarding modelling of the topping cycle follow:

1. The compressor, combustion chamber and turbine are adiabatic.
2. All components except the compressor and turbine have negligible pressure drops.
3. Fuel entering the combustion chamber only contains chemical energy and exergy.
4. The specific heat ratio “ $k$ ” is fixed at 1.4.

The work rate input to the compressor is:

$$\dot{W}_{MGT,COMP} = \dot{m}_A(h_2 - h_1) \quad [\text{kW}] \quad (4)$$

The heat loss rate of the regenerator is:

$$\dot{Q}_{LOSS,REGEN} = \dot{m}_A(h_2 - h_3) - \dot{m}_{gas}(h_5 - h_6) \quad [\text{kW}] \quad (5)$$

**Table 4.** Molar mass and chemical exergy of common constituents of combustion gases (Moran et al., 2018)

Compound	Molar mass, $M$ (kg kmol <sup>-1</sup> )	Chemical exergy, $\bar{e}_i^{ch}$ (kJ kmol <sup>-1</sup> )	Chemical exergy, $e_i^{ch}$ (kJ kg <sup>-1</sup> )
CH <sub>4</sub> (g)	16.04	831650	51838.00
H <sub>2</sub> O(g)	18.02	9500	527.33
CO <sub>2</sub> (g)	44.01	19870	451.49
N <sub>2</sub> (g)	28.01	720	25.70
O <sub>2</sub> (g)	32.00	3970	124.06

The heat input rate to the combustion chambers is:

$$\dot{Q}_{CC} = \dot{m}_{gas}h_4 - \dot{m}_A h_3 - \dot{m}_f h_f \quad [\text{kW}] \quad (6)$$

The work rate produced by the turbine is:

$$\dot{W}_{MGT,TURB} = \dot{m}_{gas}(h_4 - h_5) \quad [\text{kW}] \quad (7)$$

### Combustion Modelling

Using the given technical specifications provided by the manufacturer, the parameters of each component are analyzed. The heat input required by the module can be expressed as:


$$\dot{Q}_{CC} = \dot{m}_f \cdot q_{LHV} \quad [\text{kW}] \quad (8)$$

where  $\dot{Q}_{CC}$  is the energy requirement of the combustion chamber,  $\dot{m}_{fuel}$  is the mass flow rate of fuel, and  $q_{LHV}$  is the lower heating value of biogas, which is taken to be 22 000 kJ kg<sup>-1</sup> (Loo and Koppejan, 2010).

A mass rate balance for the combustion chamber yields:

$$\dot{m}_{gas} = \dot{m}_A + \dot{m}_f \quad [\text{kg s}^{-1}] \quad (9)$$

The biogas for this study is taken to be a mixture of 60% methane, 35% carbon dioxide and 5% nitrogen. The biogas and its combustion are modelled as follows:



Equating coefficients utilizing the air fuel ratio yields:

$$a = 0.6$$

$$b = 0.35$$

$$c = 0.05$$

$$d = m_{BG} \cdot AF_{BG} \cdot \frac{1}{M_A}$$

$$e = 2a$$

$$f = a + b$$

$$g = c + 3.76d$$

$$h = b + d - \frac{e}{2} - f$$

where  $AF_{BG}$  is the air-fuel ratio of the biogas.

### Physical and Chemical Exergy

The physical exergy of a flow is described earlier (equation 3), but chemical exergy also must be considered to analyze the fuel and exhaust combustion gases.

The total exergy into the system is the exergy of the fuel entering the combustion chamber. The fuel is assumed to enter the combustion chamber at ambient conditions, and thus only to have chemical exergy. Thus,

$$\dot{EX}_f = \dot{m}_f \cdot e_f^{ch} \quad [\text{kW}] \quad (11)$$

where the chemical exergy rate is determined based on the product of the specific chemical exergy and mass flow rate of the fuel. The specific chemical exergy of the biogas is determined based on its composition:

$$e_f^{ch} = a \cdot e_{\text{CH}_4}^{ch} + b \cdot e_{\text{CO}_2}^{ch} + c \cdot e_{\text{N}_2}^{ch} \quad [\text{kJ kg}^{-1}] \quad (12)$$

where  $a$ ,  $b$ , and  $c$  are the combustion coefficients of the biogas. The chemical exergy of selected gaseous constituents is presented in [Table 4](#).

**Table 5.** Shomate equation constants for chemical compounds (NIST, 2012), and reference entropy values (Moran et al., 2018)

Compound	$\bar{s}_0$ (kJ kmol <sup>-1</sup> K <sup>-1</sup> )	A	B	C	D	E	F	G	H
H <sub>2</sub> O(g)	188.720	30.09200	6.832514	6.793435	-2.534480	0.082139	-250.8810	223.3967	-241.8264
CO <sub>2</sub> (g)	213.685	58.16639	2.720074	-0.492289	0.038844	-6.447293	-425.9186	263.6125	-393.5224
N <sub>2</sub> (g)	191.502	19.50583	19.88705	-8.598535	1.369784	0.527601	-4.935202	212.3900	0.0
O <sub>2</sub> (g)	205.033	30.03235	8.772972	-3.988133	0.788313	-0.741599	-11.32468	236.1663	0.0

The exergy flow rate of the product gases is evaluated as follows:

$$\dot{E}X_p = \dot{m}_{gas} \cdot ex_p \quad [\text{kW}] \quad (13)$$

where the total specific exergy of the products is a summation of the contributions of the exhaust constituents and accounts for both physical and chemical exergy of each constituent, that is

$$ex_p = \sum_{i=1}^n n_i [(\bar{h}_i - \bar{h}_0) - T_0(\bar{s}_i - \bar{s}_0) + e_i^{ch}] \quad [\text{kJ kg}^{-1}] \quad (14)$$

The Shomate equations are utilized to find the change in molar specific exergy and molar specific entropy from the ambient conditions (NIST, 2012). The Shomate equations follow:

$$\begin{aligned} \bar{h} - \bar{h}_0 &= A * T + B * \frac{T^2}{2} + C * \frac{T^3}{3} + D * \frac{T^4}{4} - E * \frac{1}{T} + F - H \quad [\text{kJ mol}^{-1}] \\ \bar{s} &= A * \ln(T) + B * T + C * \frac{T^2}{2} + D * \frac{T^3}{3} - E * \frac{1}{2T^2} + G \quad [\text{kJ kmol}^{-1}] \end{aligned}$$

Here, the temperature  $T$  is 1/1000 of the specified temperature in Kelvin and  $A, B, C, D, E, F, G, H$  are Shomate constants for specific compounds. Values of these constants for the product gas constituents are given in [Table 5](#).

### Bottoming Cycle Model

An EES model for the bottoming cycle was developed to assess how the subsystems behave for various configurations, with different heat inputs from the various micro turbine exhaust streams. The number of ARS units required to meet the cooling load can be varied in the model, allowing determination of how much energy can be recovered after the ARS units for additional electricity generation with the considered ORC.

Fluid properties in the system are determined using EES fluid property information. The state point properties of the bottoming cycle are listed in [Table 3](#).

Additional assumptions regarding modelling of the bottoming cycle follow:

1. All system components are adiabatic and, except for the pump and turbine, have negligible pressure drops.
2. The exhaust gas is modelled as air.
3. Turbine and pump isentropic efficiencies within the ORC are 89%.
4. Heat exchangers are 100% efficient.
5. The ARS heat exchanger is modelled as a single heat exchanger regardless of the number of ARS units employed. Thus, it is assumed the sum of all the water flows required by the ARS units pass through the heat exchanger, are heated to the required temperature, and then branched off to  $n$  smaller streams feeding  $n$  ARS units.

Operational constraints on the system parameters include the following:

1. The temperature of the exhaust gas leaving the system (state 8) is set at 150°C to avoid water vapor condensation and formation of corrosive liquids that may damage components.
2. The ARS subsystem consists of  $n_{ARS}$  Chillii ACC50 ARS units for a given configuration. If the available energy content of the exhaust gas stream is insufficient to power all  $n_{ARS}$  ARS units for a given configuration, the configuration is considered unusable.
3. All farms can produce enough manure to generate the required quantity of biogas to run all considered turbines continuously throughout the year.

### Organic Rankine Cycle

We can write the work output rate of the ORC turbine as

$$\dot{W}_{ORC,TURB} = \dot{m}_{ORC}(h_{12} - h_{13}) \quad [\text{kW}] \quad (15)$$

the work input rate to the pump as

$$\dot{W}_{ORC,PUMP} = \dot{m}_{ORC}(h_{11} - h_{14}) \quad [\text{kW}] \quad (16)$$

the energy extraction rate by the ORC from the exhaust gas as

$$\dot{Q}_{ORC,HX} = \dot{m}_{ORC}(h_{12} - h_{11}) \quad [\text{kW}] \quad (17)$$

the energy rejection rate from the ORC condenser as

$$\dot{Q}_{ORC,COND} = \dot{m}_{ORC}(h_{13} - h_{14}) \quad [\text{kW}] \quad (18)$$

and the net electrical work output rate from the ORC as

$$\dot{W}_{ORC,NET} = \dot{W}_{ORC,TURB} - \dot{W}_{ORC,PUMP} \quad [\text{kW}] \quad (19)$$

### **Absorption Refrigerator**

The energy extraction rate by the ARS from the exhaust gas can be expressed as

$$\dot{Q}_{ARS} = \dot{m}_{ARS}(h_{10} - h_9) \quad [\text{kW}] \quad (20)$$

while the mass flow rate of water in the ARS subsystem is:

$$\dot{m}_{ARS} = 2.08 \times n_{ARS} \quad [\text{kg s}^{-1}] \quad (21)$$

where  $n_{ARS}$  is the number of 50 kW ACC50 ARS units in a considered configuration.

## **ENERGY ANALYSIS AND RESULTS**

The energy (first law) efficiency for the MGT module can be expressed as:

$$\eta_{TC,I} = \frac{\dot{W}_{MGT,NET}}{\dot{Q}_{CC}}$$

where the net work output of the MGT module is

$$\dot{W}_{MGT,NET} = \dot{W}_{MGT,TURB} - \dot{W}_{MGT,COMP} \quad [\text{kW}] \quad (22)$$

The energy efficiency of the bottoming cycle can be written as

$$\eta_{BC,I} = \frac{\dot{W}_{ORC,NET} + \dot{Q}_{cool}}{\dot{m}_{gas}(h_6 - h_8) + 3n_{ARS}} \quad (23)$$

and the energy efficiency of the overall system as


$$\eta_{sys} = \frac{\dot{W}_{MGT,NET} + \dot{W}_{ORC,NET} + \dot{Q}_{cool}}{\dot{Q}_{CC} + 3n_{ARS}} \quad (24)$$

### **Topping Cycle**

The exergy efficiency of the MGT modules can be expressed as:

$$\eta_{TC,II} = \frac{\dot{W}_{MGT,NET}}{\dot{EX}_f} \quad (25)$$

The energy and exergy efficiencies of the different turbine modules are found to be similar, with the exception of the smaller capacity 65 kW module, as seen in [Figure 2](#). The increased flow rate of fuel required for the 65 kW modules is the main contributor to the reduction in energy and exergy efficiencies. The energy efficiencies and fuel flow rates of the MGTs are from manufacturer technical specifications.



**Figure 2.** Comparison of exergy and energy efficiencies of MGT modules using biogas

The overall energy and exergy efficiencies of the system give a high level perspective, but a component analysis is required to understand the breakdown of losses for the system. A more detailed analysis is performed on the 1000 kW unit. Exergy rate balances for each of the MGT components are now provided.

Compressor:

$$\dot{m}_A ex_1 + W_{comp} = \dot{m}_A ex_2 + \dot{E}x_{D,comp} \quad (26)$$

Regenerator:

$$\dot{m}_A ex_2 + \dot{m}_{gas} ex_5 = \dot{m}_A ex_3 + \dot{m}_{gas} ex_6 + \dot{Q}_{loss} \left(1 - \frac{T_o}{T_b}\right) + \dot{E}x_{D,regen} \quad (27)$$

Combustion chamber:

$$\dot{m}_A ex_3 + \dot{E}X_f = \dot{m}_{gas} ex_4 + \dot{E}x_{D,CC} \quad (28)$$

Turbine:

$$\dot{m}_A ex_3 + \dot{E}X_f = \dot{m}_{gas} ex_4 + \dot{E}x_{D,CC} \quad (29)$$

The exergy analysis locates the largest sources of loss within the system. The largest destruction of exergy within the MGT system is associated with the combustion chamber. Large exergy destructions within a component identify the location and cause (e.g., friction, mixing, expansion, compression, chemical reaction) of the irreversibilities.






Figure 3. Exergy destruction of the components within the C1000 MGT unit


Figure 3 shows the exergy destructions of the system components, and the product exergy output for the bottoming cycle. A breakdown by component of the total exergy destroyed is shown for the system in Figure 4.

### Bottoming Cycle

The exergy (second law) efficiency of the bottoming cycle can be expressed as:

$$\eta_{BC,II} = \frac{\dot{W}_{ORC,NET} + \dot{Q}_{cool} \left(1 - \frac{T_0}{T_{BC}}\right)}{\dot{m}_{gas}(ex_6 - ex_8) + 3n_{ARS}} \quad (30)$$

For the 1000 kW turbine exhaust, the exergy content of the exhaust gas modelled as combustion products and as air using EES property data are listed in Table 6.



**Figure 4.** Contribution of exergy destruction within Capstone C1000 MGT system components

**Table 6.** Exhaust exergy content for two fluid models

Cooling configuration (exhaust location)	Exhaust stream temperature [C]	Exhaust exergy rate (combustion product model) [kW]	Exhaust exergy rate (air standard model) [kW]
Turbine exhaust	280	839	479
1 ARS exhaust	267	799	439
2 ARS exhaust	255	760	400
3 ARS exhaust	242	722	363
5 ARS exhaust	216	650	291
7 ARS exhaust	191	584	225
Exhaust to Atmosphere	150	492	134

Exergy balances for the bottoming cycle components are given below.

Absorption refrigeration heat exchanger:

$$\dot{m}_{gas}ex_6 + \dot{m}_{ARS}ex_9 = \dot{m}_{gas}ex_7 + \dot{m}_{ARS}ex_{10} + \dot{E}x_{D,ARS} \quad (31)$$

Absorption refrigeration internal:

$$\dot{m}_{ARS}ex_9 = \dot{m}_{ARS}ex_{10} + \dot{E}x_{D,ARS} \quad (32)$$

Organic Rankine cycle heat exchanger:

$$\dot{m}_{gas}ex_7 + \dot{m}_{ARS}ex_{11} = \dot{m}_{gas}ex_8 + \dot{m}_{ARS}ex_{12} + \dot{E}x_{D,ORC} \quad (33)$$

Organic Rankine cycle turbine:

$$\dot{m}_{ORC}ex_{12} = \dot{m}_{ORC}ex_{13} + \dot{W}_{ORC,TURB} + \dot{E}x_{D,ORC,TURB} \quad (34)$$

Organic Rankine cycle condenser:

$$\dot{m}_{ORC}ex_{13} = \dot{m}_{ORC}ex_{14} + \dot{Q}_{ORC,COND} \left(1 - \frac{T_0}{T_b}\right) + \dot{E}x_{D,ORC,COND} \quad (35)$$


Organic Rankine cycle pump:

$$\dot{m}_{ORC}ex_{14} + \dot{W}_{ORC,PUMP} = \dot{m}_{ORC}ex_{11} + \dot{E}x_{D,ORC,PUMP} \quad (36)$$

The total exergy input to the bottoming cycle in for both models is calculated as:

$$\dot{E}x_{BC} = \dot{m}_{gas}ex_6 - \dot{m}_{gas}ex_8 \quad (37)$$

where  $ex_6$  is the exergy content of the exhaust gas exiting the MGT, and  $ex_8$  is the exergy content of the exhaust gas upon its release to the atmosphere.



**Figure 5.** Exergy inputs for various ARS units. The far right column shows the total exergy input to the bottoming cycle for exhaust gases with inlet and outlet temperatures of 280°C and 150°C respectively

Similarly, the exergy input required for  $n_{ARS}$  number of ARS units is calculated as:

$$\dot{E}x_{ARS} = \dot{m}_{gas}ex_6 - \dot{m}_{gas}ex_7 \quad (38)$$

where  $ex_7$  is the exergy content of the exhaust gas leaving  $n_{ARS}$  number of ARS units, and is fixed by the energy balance equation for the  $HX_{ORC}$ .

These exergy inputs are calculated with both fluid models and shown in **Figure 5**. In **Figure 5** little difference is observed in the overall exergy input to the bottoming cycle when modelling the exhaust gas as combustion products or as air. Thus, the exergy analysis is carried out with exhaust fluid modelled as air.

Exergy destruction in each bottoming cycle component is calculated for the 1000 kW unit and is displayed in **Figure 6** for each number of ARS units considered. As more ARS units are used, the exergy destruction is seen to increase in the ARS units and ARS heat exchanger, and more exergy from the exhaust stream is used for refrigeration, leaving little for the ORC. Consequently, the exergy destruction in the ORC components decreases as more ARS units are used, leaving less exergy available for utilization in the ORC for electricity generation.

Most of the exergy destruction occurs in the heat exchangers and the ARS units. As little exergy is available to the ORC, the exergy destruction in the ORC turbine, condenser and pump are very small compared to the heat exchangers and ARS units.

Efficiencies of the standalone ARS unit are determined. The energy efficiency can be defined as:

$$\eta_{ARS} = \frac{\text{Cooling capacity}}{\text{Electrical input} + \text{Heat input}} \quad (39)$$

Using manufacturer technical specifications (SolarNext, 2008), this becomes

$$\eta_{ARS} = \frac{50}{3 + 87.96} = 55.0\% \quad (40)$$

The exergy efficiency of the ARS subsystem can be calculated internally as:

$$\psi_{ARS,int} = \frac{\text{Cooling capacity} \times \left(1 - \frac{T_0}{T_{BC}}\right)}{\text{Electrical input} + \dot{m}_{ARS}(ex_{10} - ex_9)} = 17.0\% \quad (41)$$

and flow rate of water required to drive the absorption process (SolarNext, 2008). The change in exergy of the stream through the ARS unit is considered to be the exergy input in calculating the internal efficiency.

The change in exergy of the exhaust gas stream across the heat exchanger  $HX_{ARS}$  is considered to be exergy input in calculating the external exergy efficiency of the ARS sub-system as per equation 42. The external efficiency is of particular interest as it can be used to evaluate how well the waste heat stream is being converted into useful work rather than the internal efficiency which is irrespective of the driving heat source.




Figure 6. Exergy destruction in bottoming cycle components for C1000 turbine configurations




Figure 7. Boundaries for exergy efficiency of ARS subsystem. Dotted line denotes boundary for  $\psi_{ARS,ext}$  and dashed line denotes boundary for  $\psi_{ARS,int}$


The external exergy efficiency of the ARS subsystem can be calculated as:

$$\psi_{ARS,ext} = \frac{\text{Cooling capacity} \times \left(1 - \frac{T_0}{T_C}\right)}{\text{Electrical input} + \dot{m}_{gas} (\dot{e}x_6 - \dot{e}x_7)} \quad (42)$$

where  $T_C$  and  $T_H$  are the boundary temperatures for heat transfer of the hot and cold streams of the unit. Also,  $T_H$  is taken as the average temperature of the hot water stream the ARS requires, while  $T_C$  is taken to be the nominal cold temperature to which the milk is cooled (4°C).

Two definitions of the exergy efficiency, for which the boundaries are illustrated in Figure 7, are considered:

1. Internal exergy efficiency of ARS unit  $\psi_{ARS,int}$ . The exergy of the hot stream of water required to run the unit is the input and the exergy of the 50 kW cooling capacity is the output. This exergy efficiency is a constant 17.0%, as it does not consider the exergy of the source providing the heat.



**Figure 8.** Boundaries for exergy efficiency of ORC subsystem. Dotted line denotes boundary for  $\psi_{ORC,ext}$  and dashed line denotes boundary for  $\psi_{ORC,int}$

**Table 7.** C1000 turbine configuration efficiencies (in percent)

Energy and exergy efficiencies of C1000 with variable ARS units										
Number of ARS units $n_{ARS}$	$\eta_{ORC}$	$\psi_{ORC,int}$	$\psi_{ORC,ext}$	$\eta_{ARS}$	$\psi_{ARS,int}$	$\psi_{ARS,ext}$	$\eta_{BC}$	$\psi_{BC}$	$\eta_{SYS}$	$\psi_{SYS}$
1	4.10	37.82	15.74	54.97	16.96	8.88	9.25	10.59	32.41	29.86
2	4.10	37.82	16.05	54.97	16.96	9.00	14.37	10.65	33.71	29.78
3	4.10	37.82	16.38	54.97	16.96	9.12	19.45	10.70	35.01	29.69
5	4.10	37.82	17.14	54.97	16.96	9.40	29.51	10.80	37.61	29.53
7	4.10	37.82	18.03	54.97	16.96	9.72	39.43	10.91	40.22	29.37

- External exergy efficiency of ARS unit  $\psi_{ARS,ext}$ . The input here is the exergy decrease in the exhaust gas stream across the ARS heat exchanger. This definition highlights how efficiently, from an exergy point of view, the ARS subsystem is integrated into the overall system. This definition is dependent on the number of ARS units, and the exhaust flow conditions of the turbine. indicates the  $\psi_{ARS,ext}$  for each flow condition.

Similarly, energy and exergy efficiencies of the ORC subsystem are developed:

$$\eta_{ORC} = \frac{\dot{W}_{ORC,NET}}{\dot{m}_{ORC}(h_{12} - ex_{11})} \quad (43)$$


$$\psi_{ORC,int} = \frac{\dot{W}_{ORC,NET}}{\dot{m}_{ORC}(ex_{12} - ex_{11})} \quad (44)$$

$$\psi_{ORC,ext} = \frac{\dot{W}_{ORC,NET}}{\dot{m}_{ORC}(ex_7 - ex_8)} \quad (45)$$

The boundaries for the two ORC exergy efficiency definitions are shown in **Figure 8**.

The C1000 turbine configuration efficiencies for the bottoming cycle, the subsystems, and the overall system are listed in **Table 7**. The energy and exergy efficiencies for variable number of ARS units are also found in **Table 7**.

**Figure 9** shows that increasing the number of ARS units leads to higher energy efficiencies in the bottoming cycle and overall system. This is expected, as the internal energy efficiency of the ARS units is higher than that of the ORC, more energy output is produced using the exhaust gases to run the ARS units rather than operating a higher flow rate in the ORC unit, which is only 4.1% energy efficient.



**Figure 9.** Efficiencies for C1000 turbine configurations

For the same change, the exergy efficiency of the bottoming cycle increases only marginally, since the exergy content of the cooling effect of 50 kW per ARS unit is only slightly higher than the additional 3 kW of electricity required to operate the ARS units. This is illustrated by the lower 16.2% internal exergy efficiency of the ARS units vs. their 55.0% energy efficiency. Adding more ARS units increases the system energy efficiency much more than its exergy efficiency.

The difference in internal and external exergy efficiencies of the ARS and ORC subsystems suggests that the configuration of the systems can be changed to better use the energy available in the exhaust stream to produce work output. For instance, using an ARS system that has a higher temperature input requirement but a higher internal exergy efficiency would make better use of the higher exhaust temperatures available in the ARS heat exchanger.

## VALIDATION OF RESULTS AND COMPARISON

An exergy analysis for a gas turbine plant is reported (Ebadi and Gorji-Bandpy, 2005). In that study, second law analysis is used to identify the major contributors of exergy destruction within a gas turbine power cycle. Another study, (Khaliq et al., 2010), demonstrates that 65% of the total exergy destruction of the gas turbine power cycle occurs during combustion. The results from (Ebadi and Gorji-Bandpy, 2005) and (Khaliq et al., 2010) are consistent with and similar to those of the present study, which identifies the primary source of exergy destruction as the combustion chamber, and the other components within the gas turbine module contribute significantly less. An exergy analysis of a trigeneration system is performed (Ahmadi et al., 2012) and identified the heat exchanger driving an organic Rankine cycle and producing hot water was the second largest contributor of exergy destruction, with the combustion chamber being largest. These findings are consistent with the present study, which found that the cumulative exergy destruction of the heat exchangers are the second largest contributor of exergy destruction within the system. The application of exergy analysis to the dairy industry is reported (Soufiyan and Aghbashlo, 2017). The investigations clearly demonstrated the effectiveness of exergy analysis in determining irreversibilities and losses occurring in dairy processing plants in order to improve their performance. The exergy analysis results and exergy destruction trends observed in the present work are along the lines as observed for a dairy plant case, and agree (Soufiyan and Aghbashlo, 2017). The current work contributes to understanding the influence of exergy efficiencies in gas turbine power cycles with heat recovery options. This increased understanding identifies areas where modifications to the system would lead to increased exergy efficiency.

## CONCLUSIONS

An exergy analysis is carried out of a grid-independent environmentally benign dairy farm in Ontario, Canada. It is found that farm sizes between 250 and 6000 cows can have cooling and electricity needs met with a micro gas turbine ranging in capacity from 100 to 1000 kW output while maintaining similar exergy efficiencies. For each component and system configuration, sources of exergy destruction within the system are identified, as is the exergy efficiency of the system configuration. Small farm sizes with one ARS unit are found to be more exergy efficient compared to large farm sizes with more than one ARS unit by a difference of less than 0.5%. The primary source of exergy destruction within the micro gas turbine module is the MGT combustion chamber, which contributes 79% of the exergy destruction of the subsystem. Economic and environmental analyses appear to be merited to investigate the financial feasibility as well as the environmental impact of this type of multi-generation energy system.

### Nomenclature

$AF$	air to fuel ratio
$e^{ch}$	specific chemical exergy (mass based)
$ex$	specific exergy (mass based)
$\dot{E}x$	rate of exergy
$\dot{E}x_d$	exergy destruction rate
$h$	specific enthalpy (mass based)
$\bar{h}$	specific enthalpy (molar based)
$\dot{m}$	mass flow rate
$M$	molar mass
$mf$	mass fraction
$n$	number of moles
$\dot{Q}$	rate of heat transfer
$\bar{s}$	specific entropy (molar based)
$T$	temperature
$\dot{W}$	rate of work output

### Greek letters

$\eta$	energy efficiency
$\psi$	exergy efficiency

### Subscripts

$0$	ambient conditions
$A$	air
$ARS$	absorption refrigeration system
$b$	boundary
$C$	cold boundary condition
$CC$	combustion chamber
$COMP$	compressor
$COND$	condenser
$cool$	cooling effect
$ext$	external boundary
$f$	fuel
$gas$	exhaust gases
$H$	hot boundary condition
$HX$	heat exchanger
$int$	internal boundary
$LHV$	lower heating value
$MGT$	micro gas turbine
$NET$	net work output
$ORC$	organic Rankine cycle
$P$	product gases

<i>PUMP</i>	pump
<i>REGEN</i>	regenerator
<i>SYS</i>	overall system
<i>T</i>	turbine
<i>TC</i>	topping cycle
<i>TURB</i>	turbine

## ACKNOWLEDGEMENTS

The authors gratefully acknowledge the support provided by the Natural Sciences and Engineering Research Council of Canada.

## REFERENCES

- Ahmadi, P., Dincer, I. and Rosen, M. A. (2012). Exergo-environmental analysis of an integrated organic Rankine cycle for trigeneration. *Energy Conversion and Management*, 64, 447-453. <https://doi.org/10.1016/j.enconman.2012.06.001>
- Capstone Turbine Corporation. (2012). Capstone Turbine Corporation Solutions. *Capstone Turbine Corporation*. [Online]. Available at: <http://www.capstoneturbine.com/prodsol/solutions/chp.asp> (Accessed 30 June 2018).
- Clarke, S. and House, H. (2010). Using Less Energy on Dairy Farms. *Ministry of Agriculture, Food and Rural Affairs, Ontario*.
- Collins, D. (2011). Competitive Advantages of being Eco-friendly. In *Business Ethics: How to Design and Manage Ethical Organizations*, New York, Wiley, pp. 345-346.
- Cuomo, M. A., Kool, E., Reddy, B. V. and Rosen, M. A. (2018). Energy modelling and analysis of a multi-generation renewable energy system for dairy farm applications. *Biofuels* (in press) <https://doi.org/10.1080/17597269.2018.1469342>
- Dowlati, M., Aghbashlo, M. and Soufiyan, M. M. (2017). Exergetic performance analysis of an ice-cream manufacturing plant: A comprehensive survey. *Energy*, 123, 445-459. <https://doi.org/10.1016/j.energy.2017.02.007>
- Ebadi, M. J. and Gorji-Bandpy, M. (2005). Exergetic analysis of gas turbine plants. *International Journal of Exergy*, 2(1), 31-39. <https://doi.org/10.1504/IJEX.2005.006431>
- Hettiarachchia, M. H. D., Mihajlo, G., William, M. W. and Yasuyuki, I. (2006). Optimum design criteria for an Organic Rankine cycle using low-temperature geothermal heat sources. *Energy*, 32, 1698-1706. <https://doi.org/10.1016/j.energy.2007.01.005>
- Jokandan, M. J., Aghbashlo, M. and Mohtasebi, S. S. (2015). Comprehensive exergy analysis of an industrial-scale yogurt production plant. *Energy*, 93, 1832-1851. <https://doi.org/10.1016/j.energy.2015.10.003>
- Khaliq, A., Choudhary, K. and Dincer, I. (2010). Exergy analysis of a gas turbine trigeneration system using the Brayton cycle refrigeration cycle for inlet air cooling. *Journal of Power and Energy*, 224(4), 449-46. <https://doi.org/10.1243/09576509JPE897>
- Loo, S. V. and Koppejan, J. (2010). *The Handbook of Biomass Combustion & Co-firing*, Washington: Earthscan.
- Moran, M. J., Shapiro, H. N., Boettner, D. D. and Bailey, M. B. (2018). *Fundamentals of Engineering Thermodynamics*, 9th ed., New Jersey: John Wiley & Sons.
- Nasiri, F., Aghbashlo, M. and Rafiee, S. (2017). Exergy analysis of an industrial-scale ultrafiltrated (UF) cheese production plant: a detailed survey. *Heat Mass Transfer*, 53, 407-424. <https://doi.org/10.1007/s00231-016-1824-3>
- National Institute of Standards and Technology (NIST). (2012). [Online]. Available at: <http://webbook.nist.gov/chemistry/>
- SolarNext AG, "chillii ACC50 - Absorption Chiller. (2008). [Online]. Available at: [www.solarnext.de](http://www.solarnext.de)
- Sorguven, E. and Ozilgen, M. (2012). Energy utilization, carbon dioxide emission, and exergy loss in flavored yogurt production process. *Energy*, 40, 214-225. <https://doi.org/10.1016/j.energy.2012.02.003>
- Soufiyan, M. M. and Aghbashlo, M. (2017). Application of exergy analysis to the dairy industry: A case study of yogurt drink production plant. *Food and Bioprocess Processing*, 101, 118-131. <https://doi.org/10.1016/j.fbp.2016.10.008>
- Spachos, T. and Stamatis, A. (2011). Thermal analysis and optimization of an anaerobic treatment system of whey. *Renewable Energy*, 36, 2097-2105. <https://doi.org/10.1016/j.renene.2011.01.020>
- Turbec, "Turbec Products," Turbec. (2012). [Online]. Available at: <http://www.turbec.com/products/products.htm> (Accessed 2 October 2012).



- Yildirim, N. and Genc, S. (2015). Thermodynamic analysis of a milk pasteurization process assisted by geothermal energy. *Energy*, 90, 987-996. <https://doi.org/10.1016/j.energy.2015.08.003>
- Yildirim, N. and Genc, S. (2017). Energy and exergy analysis of a milk powder production system. *Energy Conversion and Management*, 149, 698-705. <https://doi.org/10.1016/j.enconman.2017.01.064>